

**From:** [Elspeth Ingleby](#)  
**To:** [Hilary Saunders](#)  
**Cc:** [Planning](#)  
**Subject:** NYM/2019/0629/NM - Brickyard Cottage  
**Date:** 30 September 2019 15:17:28

---

Dear Hilary,

I have no objection to the window alterations proposed, however the detail of lighting submitted would appear to be improperly shielded given the remote location of this property. Although stated that "Proposed external light to cast downlight only" the image of light type submitted clearly shows the bulb projecting below the shielding so as to permit spill of light at least up to 90° away from the wall. The property is elevated and so particularly on the east face this could lead to considerable light spill and impact on wildlife (such as bat foraging) and local dark skies. A light where the bulb is fully shielded from horizontal spill (so as to allow light to project no more than 30-45° from the vertical) would seem more appropriate in this setting.

Many thanks,

Elspeth

**Elspeth Ingleby MA<sub>Cantab</sub> ACIEEM**

**Ecologist**

North York Moors National Park Authority

The Old Vicarage, Bondgate, Helmsley, York YO62 5BP

Telephone: 01439 772700

**From:** [Planning](#)  
**To:** [Planning](#)  
**Subject:** Comments on NYM/2019/0629/NM - Case Officer Mrs H Saunders - Received from Building Conservation at The Old Vicarage, Bondgate, Helmsley, York, YO62 5BP, via email: [building@northyorkmoors.org.uk](mailto:building@northyorkmoors.org.uk)  
**Date:** 25 September 2019 15:55:31

---

Comments made by Building Conservation of The Old Vicarage

Bondgate

Helmsley

York

YO62 5BP

via email: [building@northyorkmoors.org.uk](mailto:building@northyorkmoors.org.uk)

Phone: 01439 772700

Fax: 01439 770691

EMail: [building@northyorkmoors.org.uk](mailto:building@northyorkmoors.org.uk)

Preferred Method of Contact is: Post

Comment Type is No additional comments

Letter ID: 531006

**From:**  
**To:** [Planning](#)  
**Subject:** NYM/2019/0629/NM  
**Date:** 26 September 2019 10:32:49

---

Good Morning,

Planning application NYM/2019/0629/NM

The Council object to this application on the grounds that the flue protruding from the roof is not in keeping with the original building. Out of respect for the age of the building a chimney would be preferred. Also concerns have been raised over the size of the gable end window.

Kind regards,  
Stephanie Glasby

Fylingdales Parish Council Clerk