

From: [Elspeth Ingleby](#)
To: [Planning](#)
Subject: FW: NYM/2020/0073/AGRP - Broxa Farm
Date: 16 March 2020 15:14:54

From: Elspeth Ingleby
Sent: 16 March 2020 15:15
To: Helen Webster
Subject: NYM/2020/0073/AGRP - Broxa Farm

Hi Helen

No details are given of guttering for the new shed. I have no objection but the new building should be adequately guttered with collected rainwater being directed to storage or soakaway as appropriate to avoid running onto the yard and potentially becoming contaminated by stock or machinery movements.

Thanks

Elspeth

Elspeth Ingleby MA_{Cantab} ACIEEM

Ecologist

North York Moors National Park Authority
The Old Vicarage, Bondgate, Helmsley, York YO62 5BP
Telephone: 01439 772700