

**From:** [Elsbeth Ingleby](#)  
**To:** [Hilary Saunders](#)  
**Cc:** [Planning](#)  
**Subject:** NYM/2020/0152/AGRP - High House Farm, Lockton  
**Date:** 23 March 2020 15:01:19

---

Dear Hilary,

Please can it be ensured that adequate guttering is installed on the roof directed to water collection or soakway to avoid clean rainwater becoming fouled by machinery or stock movements in the yard and creating a source of dirty water.

Many thanks

Elsbeth

**Elsbeth Ingleby MA<sub>Cantab</sub> ACIEEM**

**Ecologist**

North York Moors National Park Authority

The Old Vicarage, Bondgate, Helmsley, York YO62 5BP