

---

**From:**  
**Sent:** 05 May 2020 12:00  
**To:** Hilary Saunders  
**Subject:** RE: NYM/2020/0253/CVC The Fish Box

Dear Hilary,

RE: NYM/2020/0253/CVC The Fish Box

Thank you for your letter yesterday. With regards to the verification check of conditions 5, 6 and 7 I can confirm the following:

1. The metal adaptors for the glass balustrade can be hidden with the timber cladding by changing the mounting system to a recessed channel. Please see the attached photo.
2. We would use a non-reflective clear glass for the balustrade.
3. The handrail can be painted Anthracite Grey, RAL 7016.

Please let me know if you require further information.

Kind regards,

Adrian Fusco



NYMNPA  
05/05/2020

