

**From:** Laura Forster  
**Sent:** 03 November 2020 18:12  
**To:** Hilary Saunders  
**Subject:** Re: RE: NYM/2020/0748/CVC

Good Evening Hilary,

I have attached photos of the lights that I have been looking at for the site. The first two are 3000k and 525 lumens and will be used to light the paths and the outside of the ancillary building. The third photo is what will be on the front of each pod, these are 3000k and 580 lumens but their curved design does mean that the light is aimed downwards.

I assume as the others have flat hooded tops this will reduce the upward light however this isn't specified in their description.

I hope this helps,

Regards,

Laura

[On Thursday, October 29, 2020, 12:52, Hilary Saunders](#)

Hi Laura,

With regards to the proposed lighting, our Dark Skies Officer has made the following comments:-

"Full cut off (zero upward light) at 800 lumens and 3000k max (2700k preferable) is fine. Their statement about PIR controls being used on all lights is also welcome. However, if the lights are not full cut off down lighters, we should stipulate 500 lumens maximum and 3000k or less, even if under the overhang. The same specification has been used at Cropton Forest Cabins which are larger than the pods and that level of lighting is ample.

Please we ask for details of the lighting models being specified? "

I'd be grateful if you would provide this additional information at your earliest convenience.

Kind regards

Hilary

H. Saunders

Mrs Hilary Saunders MRTPI  
Planning Team Leader  
Development Management  
Tel.no. 01439 772700

NYMNPA

04/11/2020



NYMNP4

04/11/2020

