
From: Laura Forster
Sent: 04 November 2020 18:33
To: Hilary Saunders
Subject: Re: RE: NYM/2020/0748/CVC

Good Evening Hiliary,

Thank you for the information on those lights - i was having trouble finding lights with full specifications but these ones look great so i will go with those if they are preferred.

Regards,

Laura

On Wednesday, November 4, 2020, 16:31, Hilary Saunders

wrote:

Hi Laura,

Please find attached comments from our Dark Skies Officer -

The lights in the images provided aren't full cut off and so should be <500 lumens as well as 3000k or less. The lights should also be on timers or sensors. Do we have specifications of lumens and colour temperature?

I've attached an example of a full cut off carriage style light and also an example of a zero upward light bollard both from ARK Lighting. The carriage style lights have been used at Rawcliffe House Farm.

I've also included a Table of lighting types now being specified by Forest Holidays for their cabins at all new sites.

Hope that helps

Kind regards

Hilary

Mrs Hilary Saunders MRTPI

Planning Team Leader

Development Management

Tel.no. 01439 772700