

From:
To: [Planning](#)
Subject: Comments on NYM/2021/0300/CVC - Case Officer Miss Kelsey Blain - Received from Building Conservation at The Old Vicarage, Bondgate, Helmsley, York, YO62 5BP,
Date: 26 May 2021 10:16:12

No objection to the proposed but note that a premix of lime putty and 1:3 will not represent historic proportions and is more likely to fail due to a lack of binder. 1:3 is the ratio of quicklime and aggregate with typically doubles in volume when slaked giving an overall ratio of 2:3.

Comments made by Building Conservation of The Old Vicarage
Bondgate
Helmsley
York
YO62 5BP

Comment Type is Comment
Letter ID: 565614