
From: Craig Hall

Sent: 26 August 2021 19:08

To: Hilary Saunders

Subject: Re: NYM/2020/0757/FL- Aislaby

Hi Hilary

Please add onto the current window application then as you previously suggested.

I'm sorry for bothering you and thought you'd pick up the email in the morning and will leave you in piece.

Regards
Craig

On 26 Aug 2021, at 19:01, Hilary Saunders
wrote:

Hi Craig,

Sorry I've lost track of what I've got and can't log into the system to see what apps I have – the conditions need to be discharged formally – you could add them to the current window application or have them dealt with through a separate discharge application – but then there would be another fee....

Thanks

Hilary

Mrs Hilary Saunders MRTPI
Planning Team Leader (Development Management)
North York Moors National Park
The Old Vicarage
Bondgate
Helmsley
York
YO62 5BP

www.northyorkmoors.org.uk

From: Craig Hall
Sent: 26 August 2021 18:56
To: Hilary Saunders
Subject: RE: NYM/2020/0757/FL- Aislaby

Hi Hilary

Thanks for your reply and I'm pleased the stone sample is ok for us to proceed. I take on board your desire to see more tight pointing on the stone and not protrude so with this good advice I will instruct the builder to point in a concave manner.

As for your comment on discharging, I'm a bit naïve and new to this, are you

suggesting we wait until we resolve the window condition either way then discharge conditions 6,7,9,11 & 12 (stone sample, windows, pantiles, doors).

Kind regards
Craig Hall

From:
Sent: 26 August 2021 17:54
To:
Subject: RE: NYM/2020/0757/FL- Aislaby

Thanks – yes sorry absolutely manic here!

Do you want me to add these details to your current application to avoid you having to pay for another discharge of condition application?

The stone looks good but the pointing in one of the photos projects beyond the stone – the pointing should be recessed like in the first photo.

Thanks

Hilary

Mrs Hilary Saunders MRTPI
Planning Team Leader (Development Management)
North York Moors National Park
The Old Vicarage
Bondgate
Helmsley
York
YO62 5BP

Customer Services: 01439 772700

www.northyorkmoors.org.uk

From: Craig Hall
Sent: 26 August 2021 15:05
To: Hilary Saunders
Subject: NYM/2020/0757/FL- Aislaby

Hi Hilary

Hope you've had a nice few days off and the batteries recharged?

I was wondering if you have had time to look at the photos I sent with ref to the 1m² sample of stone and samples along with the tile?

Kind regards
Craig Hall