
From: Neil Duffield
Sent: 27 October 2021 16:06
To: Kelsey Blain
Cc: 'Christine Maw'
Subject: RE: Planning northfield granary Suffield ER11893- nymnp and client mortar 27-10-21

Hi Kelsey,
Yes, sharp sand would be preferred.
Thank you for your quick response.

Kind regards
Neil

From: Neil Duffield
Sent: 27 October 2021 15:24
To: Kelsey Blain
Cc: 'Christine Maw'
Subject: RE: Planning northfield granary Suffield ER11893- nymnp and client mortar 27-10-21

Further to our conversation we Propose a 1;3 Quicklime to sand mix.
The quicklime such as the 'Calbux 90' from Celtic sustainables is to be used. Sand complying with BS EN 13139.

I hope this clears up any outstanding queries.

Kind regards
Neil