

From: —
Subject: RE: NYM/2021/0897/CVC
Date: 19 January 2022 13:58:00

Hi Hilary

As per the updated supporting information I can confirm that the proposed 'forum nesso single downlight fitted with 2700k bulb maximum 500 lumens and separate sensor fitted on the wall above each exterior door' meets our dark skies requirements.

Kind regards
Mike

From:

Subject: RE: NYM/2021/0897/CVC
Date: 12 January 2022 15:26:00

Hi Hilary

Apologies for the delay in replying. Is this application still live?

I'm assuming the image of a floodlight in the supporting documentation is supplied for the purpose of approval?

The light wouldn't be suitable due to the fact the sensor can't be moved independently of the light and so angling the light down would render the sensor useless. There's also no specification on colour temperature or lumens output. Can we request information on where the light is to be used and for what purpose so that I might advise on suitable alternatives?

Kind regards
Mike

**NORTH YORKSHIRE COUNTY COUNCIL
BUSINESS and ENVIRONMENTAL SERVICES**



**LOCAL HIGHWAY AUTHORITY
CONSIDERATIONS and RECOMMENDATION**

Application No: **NYM21/0897/cvc**

Proposed Development: Application for verification check of conditions 6, 7, 8, 9, 11, 17 and 18 of planning approval NYM/2021/0208/FL

Location: Land between Windyridge and Mount Pleasant, Egton

Applicant: David Pickering

CH Ref: **Case Officer:** Ged Lyth

Area Ref: 4/32/160B **Tel:**

County Road No: **e-mail:**

To: North York Moors National Park Authority
The Old Vicarage
Bondgate
Helmsley
YO62 5BP

Date: 6 January 2022

FAO: Hilary Saunders **Copies to:**

From the list of conditions applied for to be verified, only condition nr. 17 is highway related.

On the clear understanding that the path shown in the plan showing the outside lighting details, will remain in place and that the pedestrians will have authority to cross the neighbours land to access the public highway, there are no highway objections.

Signed:

Ged Lyth

Issued by:

Whitby Highways Office
Discovery Way
Whitby
North Yorkshire
YO22 4PZ

**LOCAL HIGHWAY AUTHORITY
CONSIDERATIONS and RECOMMENDATION**



Continuation sheet:

Application No:

NYM21/0897/cvc

For Corporate Director for Business and Environmental Services

e-mail: