

From:

Subject: Comments on NYM/2022/0175 - Case Officer Miss Lucy Gibson - Received from Building Conservation at The Old Vicarage, Bondgate, Helmsley, York, YO62 5BP, via email: building@northyorkmoors.org.uk

Date: 06 April 2022 12:31:32

3 The Esplanade, Robin Hood's Bay
NYM/2022/0175 & NYM/2022/0183

Listed Building consent for installation of replacement front and rear doors

Consultee response:

Reviewing this application and the proposal to replace the front and rear doors, I agree in principle to the 'accurate' replacements as clearly the doors are badly rotten, and repair would be folly at this stage.

However, I require the applicant to transfer and reinstate as much of the original ironmongery as possible. If this is beyond practical, I ask that any new replacements match the originals. In addition, the applicant is to provide more detailed cross-sectional and construction details so to ensure that the new doors are indeed accurate copies. Also, the colour is replicated on the new doors.

If the applicant is planning to integrate any draught-proofing measures to improve thermal efficiency, I require them to provide details.

Comments made by Building Conservation of The Old Vicarage
Bondgate
Helmsley
York
YO62 5BP

uk

Preferred Method of Contact is: Post

Comment Type is Comment
Letter ID: 585178