
From: Samuels, Angela
Sent: 12 August 2022 15:07
To: Rob Smith
Cc: Bell, Charlie James Cox
Subject: Ladycross Phase 5 Piling Rig Specification

[OFFICIAL]

Hello Rob

It was good to see you in the meeting earlier today.

As requested, please find below our response to your question regarding the specification of the piling rig for the Phase 5 works at Ladycross.

Within the CMS, at section 3.3.3, the contractor has stated that a piling rig with a mast height of 28.4m will be used for the piling operations. This is the Basic version of the rig which is detailed in the data sheet appended to the report. This rig will be used for the majority of the piling works.

However, there are two deeper piles to be installed which will require the use of the Upgrade version rig. This rig has a mast height of 33.4m. The work to install the two deeper piles is expected to last for approximately 2 days and during this time, the Basic rig will either be demobilized and removed from site, or the mast lowered in order that it is not in operation.

I hope this clarifies the situation but if you need anything further please let me know.

Best regards

Angela Samuels
Permitting Officer
Woodsmith Project



CROP NUTRIENTS
Resolution House, Lake View, Scarborough YO11 3ZB
United Kingdom

www.uk.angloamerican.com
A member of the Anglo American plc group