

From:
To: [Planning](#)
Subject: Comments on NYM/2022/0661 - Case Officer Miss Lucy Gibson - Received from Building Conservation at The Old Vicarage, Bondgate, Helmsley, York, YO62 5BP,
Date: 14 September 2022 15:20:35

Endways, Silver Street, Robin Hood's Bay

NYM/2022/0661 – CVC

Verification check of conditions 4, 6 and 7 of planning approval NYM/2021/0948

Consultee response

Condition 4 – No issue with the provided plans, this condition can be discharged.

Condition 6 – The details for the lintel have been provided and no issue, this condition can be discharged.

Condition 7 – The use of lime mortar is welcomed, the applicant notes that our lime guidance will be followed.

I only ask that NHL lime not be used on this occasion, either lime putty or hot lime. This condition can be discharged following a small amendment in the provided details.

Comments made by Building Conservation of The Old Vicarage

Bondgate

Helmsley

York

YO62 5BP

Comment Type is Comment

Letter ID: 594717