

From:
To: [Planning](#)
Subject: Comments on NYM/2022/0655 - Case Officer Mrs Jill Bastow - Received from Building Conservation at The Old Vicarage, Bondgate, Helmsley, York, YO62 5BP,
Date: 07 October 2022 11:53:11

Newgate Farm, Rice Gate, Hackness

NYM/2022/0655

Verification check of condition 9 of planning approval NYM/2019/0619/FL

Consultee response

9) Required detailed plans showing constructional and cross-sectional details including means of opening, for all new and replacement windows and doors.

No comment on the submitted window details in general, apart from to ask that if horns are proposed on the vertical sliding sashes, they be omitted. Horns are a development of the Victorians when glazing units became larger, with the horns providing structural stability. Horns on multi-pane sashes are a false design detail and do not accurately represent (historically) this type of window.

In addition, as only window details have been provided, only part of the condition can be discharged. Door details will still need to be submitted as and when the applicant is ready.

Comments made by Building Conservation of The Old Vicarage

Bondgate

Helmsley

York

YO62 5BP

Preferred Method of Contact is: Post

Comment Type is Comment

Letter ID: 594780