

**From:**  
**To:** [Planning](#)  
**Subject:** Comments on NYM/2022/0744 - Case Officer Mr A Muir - Received from Building Conservation at The Old Vicarage, Bondgate, Helmsley, York, YO62 5BP,  
**Date:** 26 October 2022 15:58:04

---

Coach House Cottage, New Road, Robin Hoods Bay

NYM/2022/0744

Verification check of condition 3 of Listed Building consent NYM/2022/0548

Consultee response

Reviewing the submitted drawings for the rear elevation replacement windows, as they follow the design details of the existing historic Yorkshire sliding sash seen on the landing, they will be an enhancement over the existing and I fully support. I do however ask that the applicant ensures that any pointing around the timber-to-stone junction be done in lime and not cement. A quicklime would be sufficient, a mix of 1:2½ lime:sand (sand mix of 50% sharp sand and 50% builders sand) is acceptable.

Comments made by Building Conservation of The Old Vicarage

Bondgate

Helmsley

York

YO62 5BP

Preferred Method of Contact is: Post

Comment Type is Comment

Letter ID: 596944