

**From:** [Rob Smith](#)  
**To:** [Planning](#)  
**Subject:** RE: NYM/2022/0801  
**Date:** 14 November 2022 11:05:06

---

With regard to the lighting unit proposed this does not fully meet the requirement of the planning condition in terms of compatibility with dark skies objectives. Although the applicant states that the units would be positioned downwards they are not specifically zero upwards light units. They also appear to be fitted with a 4000k bulb whereas the objective should be to install a unit with a maximum 3000k bulb if possible. Furthermore, whilst the applicant states that the lights would not be left on overnight it would be preferable if this intention could be backed up by ensuring that the lights are installed with a timer or other sensor arrangement fitted, to ensure that they are not unintentionally left on when not required.

Whilst the Authority is not in a position to recommend any particular supplier or products for appropriate lighting units, the following link provides a relatively low cost example of a more compatible unit and the applicant should be requested to review the options available and provide lighting which meets this or a similar specification.

[30W Skyline Cosmos Asymmetric LED Floodlight - 3000K - BELL Lighting](#)

Kind regards

Rob

Rob Smith  
Senior Minerals Planner

North York Moors National Park Authority  
The Old Vicarage  
Bondgate  
Helmsley  
York  
YO62 5BP

---