

**From:**  
**To:** [Planning](#)  
**Subject:** Comments on NYM/2023/0055 - Case Officer Miss Megan O'Mara - Received from Building Conservation at The Old Vicarage, Bondgate, Helmsley, York, YO62 5BP,  
**Date:** 10 February 2023 14:00:01

---

Please could the applicant clarify the following two points please:

1. Condition 5 - Noted that clay pipes to be used for the weep holes but could the applicant clarify that the pipe will project from the face of the bridge? We just want to ensure that any moisture from this pipe is sufficiently dispelled away from the structure not to cause issues in the future.
2. Condition 6 - It is noted that the existing stones are to be reused in the rebuild. Please could the contractor confirm that a full record of the stones and their order will be taken prior to dismantling (usually numbered) to ensure they are replaced in the same order.

If the above could be clarified then Conditions 5 and 6 can be discharged.

Comments made by Building Conservation of The Old Vicarage  
Bondgate  
Helmsley  
York  
YO62 5BP

Preferred Method of Contact is: Post

Comment Type is Comment  
Letter ID: 601577