

From:

To:

Subject: Comments on NYM/2024/0375 - Case Officer Mrs Annabel Longfield-Reeve - Received from Building Conservation at The Old Vicarage, Bondgate, Helmsley, York, YO62 5BP, via email:

Date: 13 June 2024 15:58:56

No Objection as the works will be like for like

Can the following conditions be placed:

Materials to be like for like (York Stone) and
BCMT05 Pointing (RSN BCMT01)

All pointing in the development hereby permitted shall accord with a specification which has been approved in writing by the Local Planning Authority. The mortar mix proposed should be based on a typical mix of a non-hydraulic quicklime mortar mixed at a ratio of 1:3 (dry non-hydraulic quicklime: sand) and include the method of application and finish. A sample area may also be required by the Local Planning Authority. The pointing shall thereafter be so maintained in that condition in perpetuity.

Comments made by Building Conservation of The Old Vicarage
Bondgate
Helmsley
York
YO62 5BP

Preferred Method of Contact is: Post

Comment Type is Comment
Letter ID: 625411