

From: planning@northyorkmoors.org.uk
To: [Planning](#)
Subject: Comments on NYM/2018/0344/NM - Case Officer Miss Helen Webster - Received from Building Conservation at The Old Vicarage, Bondgate, Helmsley, York, YO62 5BP, via email: building@northyorkmoors.org.uk
Date: 12 June 2018 16:52:09

No objection to principal proposals. Please seek minor amendments to retain the traditional boarded front door or a like for like replacement with wide boards with cock bead; and to clarify the design of the conservatory which is currently shown with both flush fitting and stormproof casements to the sections whereas the elevations do not detail which lights are opening. Flush fitting casements should be used in the traditional greenhouse style where required but the number of casements should be minimised to preserve the simple utilitarian character of construction. Otherwise, please replicate all previously-applied conditions.

Comments made by Building Conservation of The Old Vicarage

Bondgate
Helmsley
York
YO62 5BP
via email: building@northyorkmoors.org.uk
Phone: 01439 772700
Fax: 01439 770691
EMail: building@northyorkmoors.org.uk
Preferred Method of Contact is: Post

Comment Type is Comment
Letter ID: 500724