

**From:** [Planning](#)  
**To:** [Planning](#)  
**Subject:** Comments on NYM/2018/0452/CVC - Case Officer Miss Harriet Frank - Received from Building Conservation at The Old Vicarage, Bondgate, Helmsley, York, YO62 5BP, via email: [building@northyorkmoors.org.uk](mailto:building@northyorkmoors.org.uk)  
**Date:** 25 July 2018 14:19:36

---

I have no objections to the proposed scheme of works. Regarding the details that have been clarified I am content for the works to commence.

This condition cannot be fully discharged however until all the details have been finalised. For example the inspection by the specialist roof contractor conducted and details of the works discussed and approved.

The specification lists a mortar of lime sand 1:2.5 ratio. Yet, there is no mention to the specific lime used. I would recommend a hot-mix or lime putty in this instance.

Comments made by Building Conservation of The Old Vicarage

Bondgate

Helmsley

York

YO62 5BP

via email: [building@northyorkmoors.org.uk](mailto:building@northyorkmoors.org.uk)

Phone: 01439 772700

Fax: 01439 770691

EMail: [building@northyorkmoors.org.uk](mailto:building@northyorkmoors.org.uk)

Preferred Method of Contact is: Post

Comment Type is Comment

Letter ID: 503796