

From: [Harriet Frank](#)
To: [Planning](#)
Subject: FW: 5006262 - Fyling Hall School
Date: 16 August 2018 11:41:18

From: Building
Sent: 15 August 2018 14:18
To: Harriet Frank
Cc: Maria Calderon
Subject: RE: 5006262 - Fyling Hall School

Thanks Harriet

Given the poor condition of the wall and insensitive alterations which have been carried out in the past we are minded to not to object to the blockwork retaining wall in this instance as we feel the public benefits would outweigh the harm.

We would however request that a more sympathetic mortar mix is considered rather than the NHL and cement pointing proposed. Alternative suggestions would be the use of a hot lime mix consisting of 1:1:6 (NHL5:quick lime:sand) or alternatively a 1:1:3 (lime:pozzaline:sand) which has been used in a very exposed location elsewhere in the NP so should be acceptable for the location and use. Attached is further advice on the use of hot lime mixes which can be passed on to the agent/contractor. Depending on timescales we can condition lime mortar mix to be approved, so that we can agree this prior to rebuilding works but would allow them to start the work in the meantime.

Also, please could you request that a photographic survey is taken throughout the dismantling of the wall as a record of its construction and this be sent to the Authority so that we can add this to the HER record.

Thanks, Clair.

Clair Shields
Planning Policy and Conservation

North York Moors National Park Authority
