

NYMNPA

11/02/2019

From: Kenneth Briscoe
Sent: 11 February 2019 13:14
To: Planning
Cc: Dan Storey
Subject: RE: Hackness C Of E Primary School, Hackness - NYM/2019/0030/FL

FAO Harriet Frank

Please find attached information requested for the above project / planning request.

As per the drawing and issued technical note, we propose to use a Klargester BIOFICIENT 23 unit based on up to 9m³/day from the school.

Regards

Ken

Kenneth R Briscoe FCIQB
Senior Building Surveyor | Building Surveying



Architecture | Building Surveying | Civil & Structural Engineering | Mechanical & Electrical Engineering | Quantity Surveying | CDM & Fire Safety Advisory | Property Advisory

Morgan House, Mount View, Standard Way, Northallerton, DL6 2YD