

**NORTH YORKSHIRE COUNTY COUNCIL  
BUSINESS and ENVIRONMENTAL SERVICES**



**LOCAL HIGHWAY AUTHORITY  
CONSIDERATIONS and RECOMMENDATION**

**Application No:** NYM16/245/OHL  
**Proposed Development:** relocation of 11kV overhead line  
**Location:** south of Dunsley Village  
**Applicant:** Northern Powergrid (Northeast Ltd)



**CH Ref:** Case Officer: Ged Lyth  
**Area Ref:** 4/37/152  
**County Road No:**

**To:** North York Moors National Park Authority  
The Old Vicarage  
Bondgate  
Helmsley  
YO62 5BP  
**Date:** 26 May 2016  
**FAO:** Cheryl Ward  
**Copies to:**

There are **no local highway authority objections** to the proposed development, however the informative below would apply.

**HI-18 INFORMATIVE - OVERHEAD CABLES**

All lengths of the overhead line crossing the publicly maintained Highway or Definitive Rights of Way are to be erected such that no part of the line comes within 6 metres of the surface of the Highway or Right of Way.

You are advised that a separate licence will be required from the Highway Authority in order to allow any works in the adopted highway to be carried out. The local office of the Highway Authority will also be pleased to provide the detailed constructional specification referred to in this condition.

|   |  |
|---|--|
| <p><b>Signed:</b></p> <p>Kay Aitchison obo <b>Ged Lyth</b></p> <p><i>For Corporate Director for Business and Environmental Services</i></p> | <p><b>Issued by:</b></p> <p>Whitby Highways Office<br/>Discovery Way<br/>Whitby<br/>North Yorkshire<br/>YO22 4PZ</p> |
|---|--|