

Condition 7. Measures to be taken to limit the transmission of noise to adjacent properties.
The measures to be taken are as follows

1. The units will have an internal walls built out of Thermalite blocks.
2. The roofing sheets will be of an insulated kind. (See photograph)
3. Large doors to be closed if loud machinery is to be used.

Condition 9. Details of the bricks to be used in the construction.

Please find the enclosed photographs of the brick samples, they are an exact match to the 3 existing industrial units in the same yard.

Condition 11. Details of the finish of the external doors.

The roller shutter doors will be of steel construction and will be galvanised dipped and will be of similar appearance to the photograph.

The access doors will be made of steel and will be of a plain appearance and will also be galvanised dipped and will be of similar appearance to the photograph.

19 AUG 2016