

**Wendy Strangeway**

---

**From:** Planning  
**Sent:** 25 September 2017 11:54  
**To:** Planning  
**Subject:** Comments on NYM/2017/0573/CVC - Case Officer Mrs J Bastow - Received from Building Conservation at The Old Vicarage, Bondgate, Helmsley, York, YO62 5BP,

Window details appear to show stormproof casements which are a non-traditional form of construction. Please amend to flush fitting casements.

Comments made by Building Conservation of The Old Vicarage Bondgate Helmsley York YO62 5BP

Preferred Method of Contact is: Post

Comment Type is Comment  
Letter ID: 483906

NYMNPA  
25 SEP 2017