

From: [Ailsa Teasdale](#)
To: [Planning](#)
Subject: FW: Lowdale Hall, Lowdale, Sleights - NYM/2017/0807/FL
Date: 27 March 2018 10:11:12

-----Original Message-----

From: Mark Antcliff
Sent: 23 March 2018 16:42
To: Conservation
Cc: Ailsa Teasdale
Subject: RE: Lowdale Hall, Lowdale, Sleights - NYM/2017/0807/FL

Tree report is fine. Please can we ensure that if approved the tree protection details and construction details are followed precisely. There is one change to the report the architect makes in substituting the recommended block paving for a gravel wearing course. In this case it is important to retain the geotextile separation layer between the clean angular stone filling the cellular confinement grid and the gravel wearing course.

Please can we also confirm that no services are to pass through any of the Tree RPA's

A no dig system has been correctly specified - The new access drive will be 300mm higher than the existing drive - is this achievable?

Thanks

Mark

Mark Antcliff
Woodland Officer
North York Moors National Park Authority

NYMNPA

23/03/2018