

From: [Planning](#)
To: [Planning](#)
Subject: Comments on NYM/2018/0120/LB - Case Officer Mrs Ailsa Teasdale - Received from Building Conservation at The Old Vicarage, Bondgate, Helmsley, York, YO62 5BP, via email: building@northyorkmoors.org.uk
Date: 25 April 2018 13:09:43

The proposed amendments to the existing building represent the product of pre-application discussions and amend a previous approval which was intended to address unauthorised works to the listed building. I have no objection to the use of slate to the roof. I object to the elevated pathway extending in front of the extension which distorts the form of the original cow walk and should be removed to re-instate the historic alignment and would request that this is omitted from the approval and appropriate conditions applied to require the entirety of the approval to be implemented to avoid the risk of harmful elements of the unauthorised extension, such as excess windows, being retained. Please also require masonry to match existing and lime mortar to be used.

Comments made by Building Conservation of The Old Vicarage

Bondgate
Helmsley
York
YO62 5BP
via email: building@northyorkmoors.org.uk
Phone: 01439 772700
Fax: 01439 770691
EMail: building@northyorkmoors.org.uk
Preferred Method of Contact is: Post

Comment Type is Raise Concerns
Letter ID: 494407

NYMNPA

25/04/2018