

Scarborough Borough Council Engineering Department

Planning Comments

File Nym	2018	0177	FL
----------	------	------	----

Application Details

CONSTRUCTION OF A "NEW TEA HUT"
AT
"QUARTER DECK", ROBIN HOODS BAY

Comments

There are no objections to the proposal provided that;

- 1) The excavation in the toe of the slope is kept to an absolute minimum and is carried out in stages.
- 2) Surface (Roof) Water is piped to a positive outlet or to a soakaway subject to satisfactory percolation test.
- 3) Any land drainage uncovered in the works remains in place and/or diverted to the satisfaction of this Authority.

Have you made the right connections?

**Cross connections are polluting our rivers and beaches.
Want to find out if your property is misconnected visit
www.connectright.org.uk**

Name,

Date

30th April 2018

