







- EXISTING POLE TO REPLACE IN LOCATION
- EXISTING OVERHEAD TO BE DISMANTLED
- RECONDUCTOR WITH 3x 100mm AAAC
- NEW POLE LOCATION
- PROPOSED NEW HV UNDERGROUND CABLE ROUTE
- BUSHES/TREES TO TRIM/LIMB/FELL
- WATER PIPE MARKER POST
- PROPOSED NEW HV OVERHEAD ROUTE

**CE Electric UK**

Lloyds Court, 78 Grey Street, Newcastle Upon Tyne, NE1 6AF

**WHITBY WEST DEV PLAN PHASE 3  
GOATHLAND - GROSMONT 11KV RING  
3X 100 AAAC MAIN LINE REBUILD**

Manufacturer Details	Scale: 1:2500
Prepared By: Pauline Moore	Type: PLANNING
Revised: 18/07/07	Grid Reference: NZ8302
Date Issued: 08/08/08	Checked By: J VIESER

Ref No: C934106	System: SYSTEM
Revision: B	Historic Org. No: C934102
Notes: 9815068 D107705	

Based on the Ordnance Survey Map with the sanction of the controller of HM Stationery Office. Crown copyright reserved.  
Licensee: CE Electric UK (Trading Company)  
Registered Office: Lloyds Court, 78 Grey Street, Newcastle upon Tyne, NE1 6AF  
Registration in England and Wales No 3478294

NYM/PA  
NOI 2007

4. Does the proposed development involve the demolition, alteration or extension of a building of special architectural or historic interest included in a list compiled or approved under section 1 of the Planning (Listed Buildings and Conservation Areas) Act 1990?

NYMNP  
 Listed  
 NOV 2007

**NOTES:** This Form is for use in connection with an application for the Secretary of State for the Department of Trade and Industry's consent under section 37 of the Electricity Act 1989 to install and keep installed above ground an electric line of a nominal voltage of less than 132 kilovolts. The Form should be sent in quadruplicate to each District / Borough Council in whose area the proposed development would be situated.

**DETAILS OF APPLICANT**

Name: **SIMON BEWSHER**  
 Address: **BELINBOROUGH / 11914 / OH**  
**6 TABLEY COURT**  
**MOSS LANE, KNUTSFORD**  
**CHESHIRE, WA16 0PL**  
 Telephone: **(On behalf of NEDL)**  
**01565 654914**  
 Grid Ref **NZ 8265,02396**  
**NZ 82646,03476**

Applicant's reference: **B/9815607**

**(PART 1)**

Date: **10 Oct 2007**

To the Chief Executive **NORTH YORKSHIRE MOORS NATIONAL PARK**

Authority

Dear Sir

Electricity Act 1989

NYMNP  
 - 1 NOV 2007

Application is being made to the Secretary of State for the Department of Trade and Industry for his consent to the development described overleaf. The Secretary of State will at the same time be requested to direct that planning permission for this development shall be deemed to be granted. The consent and the direction may be given subject to conditions.

To assist the Secretary of State to determine the application **The North Yorkshire Moors National Parks Authority District / Borough Council** is requested to return to me two copies of this Form with Part 1 Certificate and Part 11 completed and signed together with one certified plan.

Department of the Environment Circular 14/90 (Welsh Office Circular 20/90) (Department of Energy Circular 1/90) describes this procedure and the reason for it.

Yours faithfully

For and on behalf of the applicant.

**CERTIFICATE**

(To be completed by or on behalf of the District / Borough Council)  
 The **North Yorkshire Moors National Park Authority / District / Borough Council**

(i) \*object on the grounds set out below  
 have no objection to make to the development described overleaf.

(ii) \*request  
 do not request that a planning inquiry be held pursuant to paragraph 2 of Schedule 2 to the Electricity Act 1989 before the Secretary of State reaches his decision on the application.

Dated **10 Oct 2007**

Signed **[Signature]**

\* Delete as appropriate

Designation

**Borough Council**

On behalf of the North Yorkshire Moors National Park Authority / District / Borough Council  
 (Reasons for objections)

Date: **20** Signed

(Designation)

On behalf of the **Council**  
 (Local planning authority for the area in which the proposed development is to be carried out)

Two completed copies of this Form, both signed, together with a certified plan, should be returned to the applicant for submission by him to the Department of Trade and Industry.

(To be completed by the applicant)

Application is being made

- 1 NOV 2007

- (a) for consent under section 37 of the Electricity Act 1989 to install or keep installed an electric line above ground.
- (b) ~~for a direction under SECTION 90(2) OF THE TOWN & COUNTRY PLANNING ACT 1990 that planning permission for the proposed development be deemed to be granted.~~

1. Particulars of proposed development. (These particulars should be accompanied by such plans as may be necessary to enable the local planning authority to identify the land affected by the proposals and to appreciate the nature and extent of the proposed development and by a copy of the environmental statement if the applicant has prepared one.)

Due to the age and condition of various lines around the Whitby area, the networks resilience needs to be improved, in particular the line between Goathland and Grosmont. This work will provide substantial support for the network enhancing system security and improve customer service. This entire line is within the North Yorkshire Moors National Park. NEDL intend to rebuild the overhead line in its existing position. The existing copper conductor will be replaced by all aluminium alloy conductor (AAAC), a change that will be indistinguishable to the naked eye save for the profile changing from trident to flat formation. Small sections however will be re-conducted to insulated conductor in highly wooded areas.

Drawing No. 934102 Sheet 2 Rev B

There is an additional support at position 1.

In order to carry out these works a minor diversion is necessary involving the removal of span 9 to 1 Goathland Bradley Spur and replacing it with a span from pole 10 to 1 of the Goathland Bradley Spur. This facilitates a change of conductor to insulated conductor through the wooded area. Similarly, a slightly different pole arrangement is required at pole 8 to change back to the AAAC.

~~The section of the line which is subject of a scheduled monument but with not affect this.~~

Drawing No. C934102 Sheet 3 Rev B

There is a short diversion to the route between poles 26 and 29 allowing the entire Greenend Spur to be removed. Owing to the improved design specifications poles 12 and 21 will be repositioned along the line and pole 22 will be an additional pole.

A minor diversion between the main line and Fairhead Greenlands Spur will be required to install a section of insulated conductor in between pole 9 and 10 (wooded area) which will result in an additional pole at position 11; and the Fairhead South Spur will be diverted slightly resulting in one addition pole.

The line is shown coloured Red together with the poles that are being replaced in the same location shown coloured Black (and circled). New poles can be identified in Red. A red chain dot line identifies the new overhead line with line being removed shown coloured blue.

The electric line is 11,000 volt and mounted upon wooden poles. The line has a total length of 3490m for the line shown on sheet no. 3 and 1110m on sheet 2. Approximately 1194m of overhead line will be permanently removed.

2. Particulars of any representations or objections which have been made to the applicant.

3. Particulars of the applicant's compliance with his duty under paragraph 1 of Schedule 9 to the Electricity Act 1989.

~~It is not considered that the line will be an improvement on the surrounding landscape as the line is being in direct replacement for the existing line. With the exception of the area of line that is to be removed, this will have a direct improvement to the local amenity.~~

Poles 9, 10 and 11 on Sheet 2 are within the North Yorkshire Moors Unit 151 and Borehole Unit 19 SSSI's. Natural England have been contact regarding this scheme and confirmed that their only concern is bird-breeding seasons, which are finished for this year. They also asked that all debris be removed from the site.

Sheet 3 identifies 12 spans being removed completely removed dramatically improving the amenity of the local area, including the North Yorkshire Moors and the Eske Steam Railway. As a result of this the 5 spur arrangement at Greenend will be changed to a 3 span direct link involving the repositioning of poles 27 and 28.

Date: 2007

For, and on behalf of the applicant

Note: This Part to be completed, dated and signed before submitting to the local planning authority

Signed  
Designation Wayleave Officer

PART II - INFORMATION AND OBSERVATIONS

(To be completed by the District / Borough Council/ National Parks Authority)

NYMNPA  
- 1 NOV 2007

Planning Reference No.

1. Names of interested parties consulted about the proposals with details of any observations received.

2. Particulars of any representation, which have been made to the local planning authority objecting to the proposals.

3. Have any general or specific restrictions been imposed by any authority on development of the land affected by the proposed development.